

GENERAL NOTES

BASIN DATA (PER MODULE):

MIN/MAX GPM RANGE	-	200/600
ACTUAL GPM	-	
HOT WATER TEMP F°	-	
COLD WATER TEMP F°	-	
WET BULB TEMP F°	-	


MOTOR DATA (PER MODULE):

BRAND	-	BALDOR (OR EQUIV.)
EFFICIENCY	-	HIGH
HP	-	3.0 / 5.0 / 7.5
KW	-	2.2 / 3.7 / 5.6
VOLTAGE	-	200 / 230 / 480 / 575
HZ	-	60
PHASE	-	3
NUMBER	-	2
POWER FACTOR	-	.61 / .63 / .68

WEIGHTS (PER MODULE):	-	3,450lbs. - 1,565 kg
DRY SHIPPING WEIGHT	-	6,090 lbs. - 2,762 kg
OPERATING WEIGHT	-	

- EXTERNAL PIPING TO BE "STAND ALONE" (INDEPENDENTLY SUPPORTED).
- ALL EXTERNAL PIPING PROVIDED BY CUSTOMER.
- FINAL CONNECTIONS TO THE COOLING TOWER MODULE MUST BE FIELD FITTED AFTER TOWER INSTALLATION TO PREVENT PIPE STRESS ON TOWER.
- NO LOAD TO BE APPLIED TO TOWER TECH TOWER OR SUMP.
- FOR APPROPRIATE WATER LEVEL REFER TO STARTUP SECTION IN TOWER TECH DESIGN, INSTALLATION & OPERATION MANUAL.
- MAKE-UP CONNECTION/FLOAT VALVE CONNECTION FLANGE IS MADE FROM HIGH QUALITY PLASTIC TO ELIMINATE CORROSION.
- THE MAXIMUM MAKE-UP INLET PRESSURE IS 26 PSIG WHEN USING A MECHANICAL FLOAT VALVE. FLOAT VALVE MAY NOT SHUT OFF AGAINST HIGHER PRESSURES.
- *THERE ARE NO MAXIMUM PRESSURE REQUIREMENTS WHEN USING AN ELECTRONIC LEVEL CONTROL AND A SOLENOID VALVE.

NOTE:
ALL GIVEN DIMENSIONS
ARE WITHIN ±1/2"



TOWER TECH

TELEPHONE: (405) 979-2100
FAX: (405) 979-2131
E-MAIL: cad@towertechusa.com
WEBPAGE: <http://www.towertechusa.com>
5400 NW 5th
OKLAHOMA CITY, OKLAHOMA 73127

**Modular
Fiberglass
Cooling Tower
Model # TTXL-i119XX**

**1-Unit Installation
TTXL-i1 Plan & Elevation
W/Folding Substructure**

© 2001 BY TOWER TECH
ALL RIGHTS RESERVED

FOR APPROVAL BY			DATE
Tower Tech Design Team			
REVISIONS			
NO.	DATE	REVISION	

DATE:	25 APR 19
DRAWING#:	XL-11-2
PROJECT#:	
CUST PO#:	
DRAWN BY:	RTB
CHECKED BY:	
PLAN & ELEVATION	2

"DRAWING IS FOR REFERENCE PURPOSES ONLY AND NOT TO BE USED FOR CONSTRUCTION"